

BOARD OF PUBLIC WORKS
MEMBERS

KEVIN JAMES
PRESIDENT

MONICA RODRIGUEZ
VICE PRESIDENT

MATT SZABO
PRESIDENT PRO TEMPORE

MICHAEL R. DAVIS
COMMISSIONER

BARBARA ROMERO
COMMISSIONER

ARLEEN P. TAYLOR
EXECUTIVE OFFICER

CITY OF LOS ANGELES

CALIFORNIA



ERIC GARCETTI
MAYOR

DEPARTMENT OF
PUBLIC WORKS

BUREAU OF
ENGINEERING

DEBORAH WEINTRAUB, AIA, LEED^{AP}
INTERIM CITY ENGINEER

1149 S. BROADWAY, SUITE 700
LOS ANGELES, CA 90015-2213

<http://eng.lacity.org>

March 13, 2014

Francisco Cenicerros
Pipe Lining Supply
2970 E La Palma Dr, Suite J
Anaheim, CA 92806

Subject: **Approval of "Pipe Lining Supply" Lateral Lining System**

Dear Mr. Cenicerros,

This is to inform you that the "Pipe Lining Supply" lateral lining system using Interplastics CORVE 8190 vinyl-ester resin is approved for use in the City of Los Angeles public right-of-way from the private property line to the main line sewer. This approval is based on the Bureau of Engineering CIPP Approval Policy dated July 1, 2011: *"Resin saturated felt CIPP products that are made from a resin that has successfully passed the pickle jar test will not be required to undergo additional pickle jar testing, provided the felt meets the specifications of ASTM D 5813, ASTM F 1216 and ASTM F 1743."* CORVE 8190 has successfully passed the "pickle jar" test in the past and we have received the infrared scan of this resin from your representative.

This approval is contingent upon:

1. The resin does not change and the felt continues to meet ASTM requirements.
2. The list of approved installers is submitted to this office at least once per year.
3. The lateral lining does not extend into the main line sewer.
4. The installation is subject to inspection by the Bureau of Contract Administration.

This approval will expire on March 13, 2016. You may apply for a two year extension of this approval 60 days before it expires. If you have any questions, please contact Kent W. Welling at 213-485-4505 or Edward Arrington at 213-485-1694.

Sincerely,

Samara Ali-Ahmad, P.E.
Engineer of Design
Wastewater Conveyance Engineering Division
Bureau of Engineering

